



SUMMARY OF BASIN CHARACTERISTICS

BASIN S-12

TABLE V-12-1

GENERAL

TOTAL BASIN AREA	(AC)	1600
TOTAL PERVIOUS AREA	(AC)	N/A
TOTAL IMPERVIOUS AREA	(AC)	N/A
LAKE AREA	(AC)	N/A
DESIGN CONTROL ELEVATION	(FT NGVD)	3.0
10-YEAR 3-DAY FLOOD ELEVATION (MINIMUM ROAD CROWN)	(FT NGVD)	6.5
100-YEAR 3-DAY FLOOD ELEVATION (MINIMUM FINISHED FLOOR ELEVATION)	(FT NGVD)	7.5

Note:

All undeveloped areas are required to have a minimum of 20% water management area and to comply with all SFWMD and SBDD Criteria.

S.F.W.M.D. PERMIT CONDITIONS

DISCHARGE CONTROL STRUCTURE	GRAVITY
DISCHARGE CAPACITY	*
RECEIVING WATER	SFWMD C-9

* Based on SFWMD Allowable Discharge of 3/4" per day per acre

CANAL

CANAL NAME		SFWMD C-9
LENGTH	(FT)	N/A
MANNING'S "n"		N/A



