



SUMMARY OF BASIN CHARACTERISTICS

BASIN S-4

TABLE V-4-1

GENERAL

TOTAL BASIN AREA	(AC)	1988
TOTAL PERVIOUS AREA	(AC)	913 (46%)
TOTAL IMPERVIOUS AREA	(AC)	512 (26%)
LAKE AREA	(AC)	563 (28%)
DESIGN CONTROL ELEVATION	(FT-NGVD)	3.5
10-YEAR 3-DAY FLOOD ELEVATION (MINIMUM ROAD CROWN)	(FT-NGVD)	6.0
100-YEAR 3-DAY FLOOD ELEVATION (MINIMUM FINISHED FLOOR ELEVATION)	(FT-NGVD)	7.5

Note:

All undeveloped areas are required to have a minimum of 20% water management area and to comply with all SFWMD and SBDD minimum design criteria.

S.F.W.M.D. PERMIT CONDITIONS (PERMIT # 06-00097-S)

DISCHARGE CONTROL STRUCTURE		PUMP STA
DISCHARGE CAPACITY	(CFS)	70
RECEIVING WATER		SFWMD C-9

CANAL

--	--	--



