

GENERAL CRITERIA FOR FOUNTAINS INSTALLED WITHIN A LAKE

FOUNTAINS, ANCHORS, POWER CABLES, CONDUITS OR ANYTHING LEADING TO THE FOUNTAIN MUST BE THREE FEET (3') UNDERGROUND AND A MINIMUM OF 42" BELOW THE LAKE'S CONTROL ELEVATION .