



NOTES:

1. WHERE SOIL CONDITIONS CANNOT BE MAINTAINED AS SHOWN ABOVE, PROVIDE APPROVED METHOD OF CONSTRUCTION.
2. SHEETING WILL BE REQUIRED AS DETERMINED IN THE FIELD.
3. BACKFILL IN 6"-12" LAYERS, TO 98% COMPACTION, WITH MATERIALS NOT LARGER THAN 3 1/2".
4. IF A CULVERT IS CORRUGATED ALUMINUM STRUCTURAL PLATE, FILTER FABRIC SHALL BE PLACED THE ENTIRE LENGTH OF THE PIPE.
5. FILTER FABRIC SHALL BE PLACED THE FULL LENGTH OF ANY SECTION OF CULVERT UNDER ASPHALT.

25

EXHIBIT



SEAL

SOUTH BROWARD DRAINAGE DISTRICT
DESIGN CRITERIA MANUAL

EXHIBIT TITLE

LAKE AND CANAL INTERCONNECT
TRENCH AND BEDDING DETAIL